

TOWN OF CORTE MADERA

Golden Hind Passage Storm Drain Pump Station and Improvements Near Cay Passage and Tradewind Passage Project No. 09-001

ADDENDUM #1

Date: June 23, 2010

Re: Revisions to the Contract Documents

1. Within the SPECIAL PROVISIONS, replace “Section 10-2.15 B. DRIVERS (4) Cooling System” (located on page 34) with the following wording:

Each unit shall be provided with an integral motor cooling system. A stainless steel motor cooling jacket shall encircle the stator housing, providing for dissipation of motor heat regardless of the type of pump installation. An impeller, integral to the cooling system and driven by the pump shaft, shall provide the necessary circulation of the cooling liquid through the jacket. The cooling liquid shall pass about the stator housing in the closed loop system in turbulent flow providing for superior heat transfer. The cooling system shall have one fill port and one drain port integral to the cooling jacket. The cooling system shall provide for continuous pump operation in liquid or ambient temperatures of up to 104°F (40°C). Operational restrictions at temperatures below 104°F are not acceptable. Fans, blowers or auxiliary cooling systems that are mounted external to the pump motor are not acceptable

This addendum issued on June 23, 2010 at 12:00 pm by:

Daniel A. Ring, Town Engineer/Public Works Director

All bidders must acknowledge receipt of this addendum on the space provided in the Bidder's Proposal (page 8 of the Bid Forms).